

# PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"

OFF NANA MAVI MAIN ROAD, LAXMINAGAR, RAJKOT-360004

CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182

Fax No:-0281-2368175

Website:-www.pgvcl.com


E-mail:-proc.pg@gebmail.com

## TENDER NO. PGVCL/RJT/PROC/HT SMC Meter Box/770

### TECHNICAL SPECIFICATION FOR SMC HT AMR Meter Box Made FROM THERMOSETTING PLASTIC

1.0	<b>SCOPE:</b> This specification covers the design, manufacturing and testing of anti-corrosive, dust proof, rust proof, shock proof, self-extinguishing property, resistant to heat, vermin & water proof, Ultra Violet Stabilized and pilfer resistant Meter Box made from Glass Reinforced Polyester Sheet Moulding Compound (SMC) confirming to IS: 13410 (1992) and attached technical specification, drawing and IS 14772:2000.
2.0	<b>QUALIFYING REQUIERMENTS:</b> (a) Offer of manufacturers having registration for tendered Item-SMC Energy Meter Boxes with any DISCOM of Gujarat shall only be accepted against tender. (b) One Sample in total conformity to this technical specification shall be submitted along with offer. Offer without sample is liable for rejection. (b) The tenderer shall submit all relevant documentary evidence supporting each qualifying requirements failing which the offer shall not be acceptable. (d) Type Test reports of NABL Accredited test house should not be older than 7 (Seven) in line with the Clause no.-5 of Technical specification shall be submitted along with offer. Offer without complete, proper and valid type test report shall be treated as non-responsive.
3.0	<b>CONSTRUCTION:</b> 3.1. The SMC HT AMR meter Box shall comprise of Moulded single Base and single doors without joints. The construction of the Box shall be of Single Base type. 3.2. The SMC HT AMR meter box shall generally comply with the provision of IS 14772. The boxes shall be suitable for outdoor/indoor application. 3.3. SMC HT AMR Meter box shall have minimum inside size of 810(H) x 350(W) x 230(D)mm and thickness minimum 2 mm. as per enclosed drawing. Color of the Box Shall be thoroughly Off White and without color coating. 3.4. The thickness of the box shall not be less than 2.0 mm on all sides including door. 3.5. The top surface of SMC HT AMR Meter box shall have tapering shape for easy flow of rainwater. Stepped tapering shall not be accepted. 3.6. The meter box shall have a groove all round to hold soft rubber gasket with Corresponding tongue in door to ensure tongue & Groove type sealing

Signature of Tenderer:		
Date:	Place:	Company's Round Seal:



# PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"

OFF NANA MAVI MAIN ROAD, LAXMINAGAR, RAJKOT-360004

CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182

Fax No:-0281-2368175


Website:-www.pgvl.com

E-mail:-proc.pg@gebmil.com

## TENDER NO. PGVCL/RJT/PROC/HT SMC Meter Box/770

	<p>arrangement in addition to Gasket sealing for protection against entry of dust and water.</p> <p>3.7. The door shall rest on the base of box in such a way that any access from outside to the meter is not possible. The door in closed position should be overlapped on collar of base such that direct entry of screwdriver or tool is not possible.</p> <p>3.8. The Box shall confirm to ingress protection level IP-53.</p> <p>3.9. All corners of the Meter box should be round and not pointed ones. In the box shall be fitted Z.P. M.S. Sliding arrangement so as to facilitate mounting of meter and TTB as shown in drawing. Vertical part of sliding arrangement should be "C" channel type with minimum 2 mm thickness.</p> <p>3.10. Thickness of horizontal Strips in sliding arrangement for mounting of meter and TTB shall be 2.0 mm(<math>\pm</math> 0.02 mm).</p> <p>3.11. Provision of mounting of GSM Modem so as to facilitate mounting modem tray on a modem self on top of meter should be provided as shown in drawing. MS Plates of 70x70 mm shall also be fitted at 2 places as shown in drawing of facilitate Modem Antenna fixing.</p> <p>3.12. SMC HT AMR Meter box door shall be fitted to base by concealed Stainless Steel Strip hinges.</p> <p>3.13. The SMC HT AMR Meter boxes shall be closed by S.S.'U' Clamp (04no.) of minimum 0.8mm (<math>\pm</math> 0.1mm) thickness for holding and locking of the door. The "U" Clamp (02no.) shall have 4mm diameter hole through which it is possible to seal the box for sealing purpose.</p> <p>3.14. For meter reading the box should have a window with Toughened/Triplex Glass Fixed with S.S. frame from inside. The box should have a window of size 280mm x 180mm provided with Glass as shown in the drawing.</p> <p>3.15. 4Nos wall/pole mounting SMC Flat having holes 12 mm diameter shall be provided on back side of Meter Box for fixing of box on the wall/pole.</p> <p>3.16. For cable entry shall be provided at Bottom of box with good quality dia 25mm brass double compression gland as shown in the drawing. Gland should be as per IS 12943:1990. Gland size should be marked on gland.</p> <p>3.17. One nos Earth bolt of 6mm diameter x 25mm length with 2 Nos Nuts and 2 nos. washers plus a spring washer shall be provided. The earthing arrangement shall be of G.I.bolt. Earthing symbol is to be provided near the earthing bolt.</p>
<b>4.0</b>	<b>GUARANTEED TECHNICAL PARTICULARS:</b> Guaranteed Technical Particulars are given in enclosed Annexure A and B. Bidder shall submit the data in given Proforma.

Signature of Tenderer:		Company's Round Seal:
Date:	Place:	



# PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"  
OFF NANA MAVI MAIN ROAD, LAXMINAGAR, RAJKOT-360004  
CIN U40102GJ2003SGC042908


Telephone Nos:-0281-2380425/427/2360182  
Website:-www.pgvcl.com

Fax No:-0281-2368175  
E-mail:-proc.pg@gebmail.com

## TENDER NO. PGVCL/RJT/PROC/HT SMC Meter Box/770

5.0	<b>TYPE TEST CERTIFICATE:</b> The bidder shall submit type test report as per IS-14772-2000 & IS-13410:1992 from CIPET, Ahmadabad/ERDA, Baroda along with the offer. Type Test Certificate should not be older than 7 years as on the date of tender opening.
6.0	<b>ROUTINE TEST:</b> Manufacturer has to carry out routine test during production to check the essential requirements which are likely to vary during production. Manufacturer has to keep records of the same and to be produced for verification of Inspector when asked at the time of inspection of LOT.
7.0	<b>ACCEPTANCE TEST:</b> The acceptance tests as per IS 14772-2000 shall be carried out on sample box selected as per sampling criteria specified in IS.
8.0	<b>RAW MATERIALS:</b> The manufacturer has to submit the test certificate for the material used in the lot offered and document for purchase of raw material.
9.0	<b>FACILITY:</b> The bidder shall have facility to test the box for routine tests and acceptance as per IS-14772:2000 and IS-13410 at their works. The bidder has to submit list of Machinery & Equipment / Testing instruments etc.
10.0	<b>INSPECTION AND TESTING:</b> The bidder has to offer the boxes for inspection at his works before dispatch. The manufacturer will offer all facilities to inspector without any charge.
11.0	<b>DISPATCH:</b> The meter boxes shall be so dispatched as to ensure that no damage occurs during transport where they may be subject to rough handling.
12.0	<b>TENDER SAMPLE:</b> A sample as per specifications will have to be submitted for the tender to the Deputy Engineer, RSO, Rajkot.
13.0	<b>DESTINATION:</b> The above material shall be supplied to the RSO of PGVCL.

Signature of Tenderer:		Company's Round Seal:
Date:	Place:	



# PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"

OFF NANA MAVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004

CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182

Fax No:-0281-2368175

Website:-www.pgvcl.com

E-mail:-proc.pg@gegmail.com


## TENDER NO. PGVCL/RJT/PROC/HT SMC Meter Box/770

### ANNEXURE -A

#### GUARANTEED TECHNICAL PARTICULARS FOR SMC HT AMR Box

	Particulars	Detailed Particulars	To be Offered by Bidder
1	Maker's name	To be intimated by the supplier	
2	Material	Glass reinforced polyester sheet moulding compound	
3	Grade of Material	SMC confirming to IS: 13410-1992 Grade S 1	
4	<b>PROPERTIES OF MATERIAL OF CONSTRUCTION OF METER BOX</b>		
	Flame Retardant test	As per IS - 11731 (Min.FVO)	
	Glow wire test at 650 C	As per IS - 11000 Part-2/sec-1	
	Degree of protection	IP-53 as per IS-12063 / 87	
	Fire Retardancy	Self Extinguishing as per IS:4249	
	Heat Distortion temp	180° C (min) as per IS: 13411	
	Dielectric Strength at 90 °C in oil	9 KV / mm (min) as per IS:6262-1971	
	Tensile Strength	50 Mpa (Min) as per Annex-F of IS-8543 (P-4/Sec-1) 1984	
	Flexural strength	155 Mpa (Min) as per Annex-F of IS-13411-1992	
	Izod Impact strength (Notched)	45 KJ/M2 (Min) as per Annex-E of IS-13410-1992	
5	<b>Inside dimension of Meter Box</b>		
	a. Height	810 mm (min)	
	b. Width	350 mm (min)	
	c. Depth	230 mm (min)	
	d. Thickness of SMC	02 mm (min)	
6	Window having Triplex Glass	Window Size 280 mm x 180 mm with Triplex glass.	
7	Fixing of Glass	Fitted from inside in such a way that it cannot be replaced without opening door (with S.S. frame all around)	
8	Locking arrangement	For holding & locking of door with base "U" shaped clamps to be provided with arrangement for sealing of box	
9	Manufacturer short name & PGVCL company logo	To be provided on the front side of the box	

Signature of Tenderer:		Company's Round Seal:
Date:	Place:	



# PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"  
OFF NANA MAVI MAIN ROAD, LAXMINAGAR, RAJKOT-360004

CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182

Fax No:-0281-2368175


Website:-www.pgvcl.com

E-mail:-proc.pg@gebmail.com

## TENDER NO. PGVCL/RJT/PROC/HT SMC Meter Box/770

	shall be embossed/printed on the front side of the box.		
10	Cable entry holes	Cable entry hole with 1 no. good quality dia 25 mm brass double compression gland as per IS 12943:1990	
11	Color of box	Toughly Off White material and without color coating	
12	Earthing Arrangement		
	Earthing bolt	One no. of Earthing bolt of MS with 2 nuts and 2 washers shall be provided on RH side of box. Earthing sign has to be provided near to Earthing bolt.	
	Dia & Length of Earthing bolts	Dia. 6 mm Length 25 mm.	
13	Accessories	6 no. of 3 mm MS nut bolts with 30 mm length and 2 washers to be provided with SMC AMR Box	
12	<b>Box weight: (in grams)</b>		
	a. Weight of SMC material	Give weight of thermosetting plastic.	
	b. Total weight of offered SMC Box	Give total weight including thermosetting plastic, glass, metal parts etc.	

Signature of Tenderer:		Company's Round Seal:
Date:	Place:	



# PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"  
OFF NANA MAVI MAIN ROAD, LAXMINAGAR, RAJKOT-360004

CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182

Fax No:-0281-2368175

Website:-www.pgvcl.com

E-mail:-proc.pg@gebmail.com

## TENDER NO. PGVCL/RJT/PROC/HT SMC Meter Box/770

### ANNEXURE - B TESTING

- 1.0 Ordered goods should be type tested at NABL approved test house for tests and parameters given in GTP/IS. The test report of more than 7 years before order date will not be accepted. The test report should be submitted to purchaser before completion of order.
- 2.0 Lot wise sampling plan: 1 no. selected randomly from lot for testing at manufacturer's works.

SR. NO.	TEST REQUIREMENT FOR METER BOX	REFERENCE STANDARDS
(A)	Marking	IS:14772
(B)	Dimensions and Construction	IS:14772
(C)	Melting Point (To test up to 400 °C)	IS:13360

Signature of Tenderer:		Company's Round Seal:
Date:	Place:	