


**NOTE :-**

1. APPLICABLE STANDARD IS 5300 / 1989
- DESIGNATION C FIG-3
2. COLOUR OF GLAZE BROWN
3. SIZE OF INSULATOR MM 140 X 85
4. LENGHT MM 140
5. DIAMETER MM 86
6. CABLE HOLD MM 25
7. MIN FAILING LOAD KN 86
8. P.F. WITHSTAND VOLTAGE DRY KV 27 (rms)
9. P.F. WITHSTAND VOLTAGE WET KV 13 (rms)
10. MARKING AS PER IS IS 5300 / 1989  
38 KN  
MONTH / YEAR
- 11 ALL DIMENSION ARE IN MM

  
 Chief Engineer (Material)  
 PGVCL, Corporate Office  
 Rajkot.

TENDER NO. PGVCL/PROC/HT-LT Stay & LT shackle Insulator/850



PASCHIM GUJARAT VIJ COMPANY LIMITED

DRAWING L

HT- STAY (GUY) INSULATOR