


NOTE: The Portion marked  shall be enlarged.
SHACKLE INSULATOR

NOTE :-

- | | |
|---|--|
| 1. APPLICABLE STANDARD | IS 1446 / 1977 |
| DESIGNATION | I FIG-3 |
| 2. COLOUR OF GLAZE | BROWN |
| 3. SIZE OF INSULATOR | MM 80 X 75 |
| 4. MIN FALLING LOAD | KN 11.5 |
| 5. P.F. WITHSTAND VOLTAGE DRY KV | 23 (rms) |
| 6. P.F. WITHSTAND VOLTAGE WET KV | 10 (rms) |
| 7. V.F. FRACTURE WITH STAND VOLTAGE WET | 1.8X The actual dry flash over voltage |
| 8. MARKING AS PER IS | IS 1446 / 1977
11 5KN
MONTH / YEAR |
| 11 ALL DIMENSION ARE | MM |

TENDER NO. **PGVCL/PROC/HT-LT Stay & LT Shackle Insulator/850**



PASCHIM GUJARAT VIJ COMPANY LIMITED

ESTABLISHED

L.T. SHACKLE INSULATOR


Chief Engineer (Material)
PGVCL, Corporate Office
Rajkot.