


NOTE :-

1. APPLICABLE STANDARD IS 5300 /1969
2. DESIGNATION FIG. 2 B
3. COLOUR OF GLAZE WHITE
4. SIZE OF INSULATOR MM 110 X 75
5. LENGTH MM 110
6. DIAMETER MM 76
7. CABLE HOLD MM 22
8. MIN FAILING LOAD KN 53
9. P.F. WITHSTAND VOLTAGE DRY KV 22 (rms)
10. P.F. WITHSTAND VOLTAGE WET KV 9 (rms)
11. MARKING AS PER IS 5300 / 1969
12. ALL DIMENSION ARE IN MM

Chief Engineer (Material)
 PGVCL, Corporate Office
 Rajkot.

TENDER NO. PGVCL/PROC/HT-LT Stay & LT Shackle Insulator/850



P
G
V
C
L

PASCHIM GUJARAT VIJ COMPANY LIMITED

DRAWING 1

L.T. STAY (GUY) INSULATOR