



NOTE :-

1. APPLICABLE STANDARD IS 5300 / 1969
2. DESIGNATION C FIG-3
3. COLOUR OF GLAZE BROWN
4. SIZE OF INSULATOR MM 140 X 85
5. LENGTH MM 140
6. DIAMETER MM 85
7. CABLE HOLD MM 25
8. MIN FAILING LOAD KN 38
9. P.F. WITHSTAND VOLTAGE DRY KV 27 (rms)
10. P.F. WITHSTAND VOLTAGE WET KV 13 (rms)
11. MARKING AS PER IS IS 5300 / 1969
12. MONTH / YEAR 88 KN
13. ALL DIMENSION ARE IN MM


 Chief Engineer (Material)
 PGVCL, Corporate Office
 Rajkot.

TENDER NO. PGVCL/RJT/PROC/HT-LT Stay & LT Shackle Insulator/798



PASCHIM GUJARAT VIJ COMPANY LIMITED

DRAWING L

HT- STAY (GUY) INSULATOR