


NOTE: The Portals marked — shall be engulged.

SHACKLE INSULATOR

NOTE :-

- | | |
|---|--|
| 1. APPLICABLE STANDARD | IS 1445 / 1977 |
| DESIGNATION | 1 FIG-3 |
| 2. COLOUR OF GLAZE | BROWN |
| 3. SIZE OF INSULATOR | MM 90 X 75 |
| 4. MIN FAILING LOAD | KN 11.5 |
| 5. P.F. WITHSTAND VOLTAGE DRY KV | 28 (rms) |
| 6. P.F. WITHSTAND VOLTAGE WET KV | 10 (rms) |
| 7. V.F. PUNCTURE WITH STAND VOLTAGE WET | 1.3K The actual dry flash over voltage |
| 8. MARKING AS PER IS | IS 1445 / 1977 |
| | 11 5KN |
| | MONTH / YERR |
| 11 ALL DIMENSION ARE | MM |

TENDER NO. PGVCL/RJT/PROC/HT-LT Stay & LT Shackle Insulator/798



PASCHIM GUJARAT VIJ COMPANY LIMITED

DRAWING NO. L

L.T. SHACKLE INSULATOR

[Signature]
 Chief Engineer (Material)
 PGVCL, Corporate Office
 Rajkot.