



NOTE :-

- | | |
|----------------------------------|----------------|
| 1. APPLICABLE STANDARD | IS 5300 /1969 |
| DESIGNATION | FIG. 2 B |
| 2. COLOUR OF GLAZE | WHITE |
| 3. SIZE OF INSULATOR | MM 110 X 75 |
| 4. LENGHT | MM 110 |
| 5. DIAMETER | MM 76 |
| 6. CABLE HOLD | MM 22 |
| 7. MIN FAILING LOAD | KN 53 |
| 8. P.F. WITHSTAND VOLTAGE DRY KV | 22 (rms) |
| 9. P.F. WITHSTAND VOLTAGE WET KV | 9 (rms) |
| 10. MARKING AS PER IS | IS 5300 / 1969 |
| 11. ALL DIMENSION ARE IN | MM |

Chief Engineer (Material)
 PGVCL, Corporate Office
 Rajkot.

TENDER NO. PGVCL/RT/PROC/HT-LT Stay & LT Shackle Insulator/798

PASCHIM GUJARAT VIJ COMPANY LIMITED

DRAWING L

L.T. STAY (GUY) INSULATOR

