TENDER No.PGVCL/PROC/SMC Fuse Box/845



SIDE VIEW





BOTTOM VIEW OF CARRIER



PART - X



TOP VIEW OF CARRIER



PART - Y



ASSEMBLY

NOTE:
1. WORD 'XXVCL' AND TRADE MARK OF SUPPLIER SHALL BE EMBOSSED BOTH ON FUSE CARRIER AND BASE
2. GENERAL TOLERANCE ± 5% ON LENGTH, WIDTH AND HEIGHT OF THE BODY.
3. CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS
   UP TO 50mm – ±1mm
   ABOVE 50mm – ±2mm
4. WALL THICKNESS
   UP TO 10mm ±1mm.
   ABOVE 10mm ±1.5mm.
5. TOLERANCE ± 5% IN CERAMIC PARTS
6. ALL CURRENT CARRYING PARTS TINNED PLATED WITH TOLERANCE AS PER IS – 2086/93 WITH LATEST AMMENDMENT.
7. ALL DIMENSIONS ARE IN mm



SIDE VIEW



PLAN

PART - Z

A/C Chief Engineer (Project)
PGVCL, Corp. Office
Rajkot

DISCOM Name: PGVCL

GENERAL ARRANGEMENT & COMPONENTS DRG. FOR 200Amp, 415Volts KIT-KAT FUSE

DRG. NO.: PGVCL/FUSE/03/200 Amp