



PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"
OFF NANA MAVVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004
CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182
Website:-www.pgvcl.com

Fax No:-0281-2368175
E-mail:-proc.pg@gebmail.com

TENDER NO. PGVCL/PROC/SMC BOX FOR CT OPERATED METER & Junction Box/867

SCHEDULE - X

TECHNICAL SPECIFICATION FOR SERVICE CONNECTION BOX MADE FROM THERMOSETTING PLASTIC FOR SERVICE CONNECTIONS.

1.0 SCOPE:

1.1 This specification covers the design, manufacturing and testing of anti-corrosive, dust proof, rust proof, shock proof, self extinguishing property, resistant to heat, vermin & water proof, Ultra Violet Stabilized and pilfer resistant Service Connection Dist. Box made from Thermosetting Plastic i.e. Glass Reinforced Polyester Sheet Moulding Compound (SMC) Confirming to IS:13410 (1992) and attached technical specification, drawing and IS 14772:2000.

2.0 CONSTRUCTION:

2.1 Service Connection Box shall be moulded in a single piece forming the body of the Service Connection Box with a cover fitted with base by minimum two nos. concealed Anticorrosive hinges. The lid/cover shall rest on the collar of the Service Connection Box base in such a way that any access from outside of the box is not possible. The hinges shall be fitted with the Service Connection Box body base and cover rigidly, thereby making the Service Connection Box pilfer resistant. All corners of the Service Connection box should be round & not pointed ones.

2.2 The door in closed position should be overlapped in such a manner that no direct entry or access is possible. The Service Connection Box shall be closed by MS 'U' Clamp of minimum 1.2 mm. thickness for holding and locking of the door with body base. The "U" Clamp shall sealing arrangement for sealing purpose.


2.3 The top surface of box shall have little tapering shape towards both sides of the Service Connection Box for easy flow of rainwater.

Signature of Tenderer

Company's Round Seal

Date:

Place:



PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"
OFF NANA MAVVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004
CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182
Website:-www.pgvcl.com

Fax No:-0281-2368175
E-mail:-proc.pg@gebmail.com

TENDER NO. PGVCL/PROC/SMC BOX FOR CT OPERATED METER & Junction Box/867

Required arrangements per box should be as follows:

| Sr. No | Details | Box for 4 nos. of 3 ph. connection | Box for 8 nos. of 1 ph. connection |
|--------|--|--|--|
| 01 | Size of the box | 250 x 250 x 160 mm | 250 x 250 x 160 mm |
| 02 | Thickness | 1.5mm | 1.5 mm |
| 03 | Opening of the box | 90° | 90° |
| 04 | No of holes on backside box wall having 6 mm dia for fixing of box. | 04 No | 04 No |
| 05 | Earth bolt of 6 mm dia x 20 mm length with 2 nuts and 2 washers | 01 No | 01 No |
| 06 | Cable Entry Hole with good quality rubber grommets as shown in drawing. | 35 mm – 01 No | 25 mm – 01 No |
| 07 | Cable Exit Holes with good quality rubber grommets as shown in drawing. | 25 mm – 04 No | 14 mm – 08 No |
| 08 | Required no of Distribution Blocks (Phase) | 03 No | 01 No |
| 09 | Required no of connection per Distribution Blocks (per Phase) | 04 No | 08 No |
| 10 | Distribution Blocks (Phase) should have arrangement for cable connection purpose | I/C–35 sq mm O/G–10 sq mm | I/C–35 sq mm O/G–10 sq mm |
| 11 | Current Carrying capacity of each Distribution Blocks (Phase) | I/C–114 AMP O/G–57 AMP | I/C–114 AMP O/G–57 AMP |
| 12 | Required no of Distribution Blocks (Neutral) | 01 No | 01 No |
| 13 | Required no of connection per Distribution Blocks (Neutral) | 12 No | 08 No |
| 14 | Distribution Blocks (Neutral) should have arrangement for cable connection purpose | I/C–04 sq mm O/G–04 sq mm | I/C–35 sq mm O/G–10 sq mm |
| 15 | Current Carrying capacity of each Distribution Blocks (Neutral) | I/C–32 AMP O/G–32 AMP | I/C–114 AMP O/G–57 AMP |
| 16 | Fixing arrangement of each Distribution Blocks (Phase & Neutral) | A fixed Alkaline Zinc Plated with Yellow Passivation DIN Channel | A fixed Alkaline Zinc Plated with Yellow Passivation DIN Channel |

Signature of Tenderer

Company's Round Seal

Date:

Place:



PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"
OFF NANA MAVVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004
CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182
Website:-www.pgvcl.com

Fax No:-0281-2368175
E-mail:-proc.pg@gebmail.com

TENDER NO. PGVCL/PROC/SMC BOX FOR CT OPERATED METER & Junction Box/867

- 3 **GUARANTEED TECHNICAL PARTICULARS:**
- 3.1 Guaranteed Technical particulars are given in enclosed Annexure A and B. Bidder shall submit the data in given Performa.
- 4 **TYPE TEST CERTIFICATE:**
- 4.1 The bidder shall submit type test report as per IS-14772-2000 & IS – 13410 : 1992 from CIPET, Ahmedabad / ERDA, Baroda along with the offer. Type Test Certificate should not be older than 5 years as on the date of tender opening.
- 5 **ROUTINE TEST :**
- 5.1 Manufacturer has to carryout routine test during production to check the essential requirements that are likely to vary during production. Manufacturer has to keep records of the same and to be produced for verification of inspector when asked at the time of inspection of lot.
- 6 **ACCEPTANCE TEST**
- 6.1 The acceptance tests shall be carried out on randomly selected samples as per Annexure-B
- 7 **TYPE TEST**
- From the offered lot, Sample shall be picked up at discretion of Company for type test at CIPET, Ahmedabad / ERDA, Vadodara pr any NABL accredited laboratory for every 10,000 nos. supply. The charges for the Type Test shall be borne by bidder. On passing the type test successfully, the lot shall be accepted. In case, the boxes are not confirmed to type test, another sample from the lot shall be selected and tested again. On receipt of unsatisfactory results, the lot shall be rejected and new lot shall be offered for inspection keeping aside old lot offered and rejected earlier by the Company. However Company reserves the right to accept the boxes by levying penalty at the discretion of the Company.
- 8 **RAW MATERIALS**
- 8.1 The manufacturer has to submit the test certificate for the material used in the lot offered and document for purchase of raw material.
- 9.0 **FACILITY**
- 9.1 The bidder shall have facility to test the box for routine tests and acceptance as per IS – 14772: 2000 and IS - 13410 at their works. The bidder has to submit list of Machinery & Equipment / Testing instruments etc.

Signature of Tenderer

Company's Round Seal

Date:

Place:



PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"
OFF NANA MAVVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004
CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182
Website:-www.pgvcl.com

Fax No:-0281-2368175
E-mail:-proc.pg@gebmail.com

TENDER NO. PGVCL/PROC/SMC BOX FOR CT OPERATED METER & Junction Box/867

10.0 INSPECTION AND TESTING

10.1 The bidder has to offer the boxes for inspection at his works before dispatch. The manufacturer will offer all facilities to inspector without any charge.

11 DESPATCH

11.1 The Service Connection Boxes shall be so dispatched as to ensure that no damage occurs during transport where they may be subject to rough handling.

12 TENDER SAMPLE

12.1 One tender sample as per specifications will have to be submitted before last date of submission of Tender to The Deputy Engineer (Regional store Office) PGVCL, Dudhsagar Road, Rajkot

Signature of Tenderer

Company's Round Seal

Date:

Place:



PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"
OFF NANA MAVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004
CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182
Website:-www.pgvcl.com

Fax No:-0281-2368175
E-mail:-proc.pg@gebmail.com

TENDER NO. PGVCL/PROC/SMC BOX FOR CT OPERATED METER & Junction Box/867

ANNEXURE – A

GUARANTEED TECHNICAL PARTICULARS

| SR. NO. | PARTICULARS | DETAILED PARTICULARS | TO BE OFFERED BY BIDDER |
|---------|--|---|-------------------------|
| 1 | Maker's name | To be intimated by the supplier | |
| 2 | Material | Glass reinforced polyester sheet moulding compound | |
| 3 | Grade of Material | SMC confirming to IS: 13410:1992 Grade S 1 | |
| 4 | Properties of Material of Construction of Service Connection Box | | |
| | Heat Deflection Temperature (Ref. Std. IS:13411) | 150°C (Minimum) | |
| | Exposure to flame (Ref. Std. IS:4249) | Self-extinguishing | |
| | Melting Point (Ref. Std. IS:13360) | Does not melt | |
| | Glow wire test at 650 C | As per IS 11000 Part-2/sec-1 | |
| | Degree of protection | IP-42 as per IS-12063 / 87 | |
| | Heat distortion temp. | 125 C (Min) as per IS:13411 | |
| | Dielectric Strength at 90 C in oil | 9 KV/mm (Min) as per IS : 6262-1971 | |
| 5 | Inside dimension of Service Connection Box | To be mentioned by the supplier | |
| | a. Height | 250 mm (min) | |
| | b. Width | 250 mm (min) | |
| | c. Depth | 160 mm (min) | |
| | d. Thickness of SMC sheet | 01.50mm (min) | |
| 6 | Earthing Arrangement | | |
| | Earthing bolt | One no. of Earthing bolt of MS with 2 nuts and 2 washers shall be provided on RH side of box. Earthing sign has to be provided near to earthing bolt. | |

Signature of Tenderer

Company's Round Seal

Date:

Place:



PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"
OFF NANA MAVVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004
CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182
Website:-www.pgvcl.com

Fax No:-0281-2368175
E-mail:-proc.pg@gebmail.com

TENDER NO. PGVCL/PROC/SMC BOX FOR CT OPERATED METER & Junction Box/867

| | | | |
|----|--|---|--|
| | Dia. & Length of earthing bolts | Dia. 6 mm Length 20 mm | |
| 7 | Locking arrangement | For Holding & Locking of door with base one no. of "U" shaped clamps to be provided | |
| 8 | Manufacturer short name & Company logo shall be Printed on the front side of the box | To be provided on the front side of the box | |
| 9 | Sealing arrangement | Holes for wire seal. | |
| 10 | Wire entry | plugged holes | |
| 11 | Colour of Service Connection Box | Off White | |
| 13 | Distribution Blocks Mounting Arrangement | Fixed Alkaline Zinc Plated with Yellow Passivation DIN Channel | |
| 14 | Distribution Blocks (Phase) | | |
| | Current Carrying Capacity (Phase) | Three Phase - 04 Consumers: Rating Incoming = 114 Amps Rating Outgoing = 57 Amps each | |
| | | Single Phase - 08 Consumers: Rating Incoming = 114 Amps Rating Outgoing = 57 Amps each | |
| | | Single Phase - 04 Consumers: Rating Incoming = 114 Amps Rating Outgoing = 57 Amps each | |

Signature of Tenderer

Company's Round Seal

Date:

Place:



PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"
 OFF NANA MAVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004
 CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182
 Website:-www.pgvcl.com

Fax No:-0281-2368175
 E-mail:-proc.pg@gebmail.com

TENDER NO. PGVCL/PROC/SMC BOX FOR CT OPERATED METER & Junction Box/867

| | | | |
|----|-------------------------------------|---|--|
| | Cable Size (Phase) | Three Phase - 04 Consumers: Incoming = Upto 35 sq.mm Outgoing = Upto 10 sq.mm Single Phase - 08 Consumers: Incoming = Upto 35 sq.mm Outgoing = Upto 10 sq.mm Single Phase - 04 Consumers: Incoming = Upto 35 sq.mm Outgoing = Upto 10 sq.mm | |
| 15 | Distribution Blocks (Neutral) | | |
| | Current Carrying Capacity (Neutral) | Three Phase - 04 Consumers: Rating Incoming = 32 Amps Rating Outgoing = 32 Amps each Single Phase - 08 Consumers: Rating Incoming = 114 Amps Rating Outgoing = 57 Amps each Single Phase - 04 Consumers: Rating Incoming = 114 Amps Rating Outgoing = 57 Amps each | |
| | Cable Size (Phase) | Three Phase - 04 Consumers: Incoming = Upto 04 sq.mm Outgoing = Upto 04 sq.mm Single Phase - 08 Consumers: Incoming = Upto 35 sq.mm Outgoing = Upto 10 sq.mm | |

Signature of Tenderer

Company's Round Seal

Date:

Place:



PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"
OFF NANA MAVVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004
CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182
Website:-www.pgvcl.com

Fax No:-0281-2368175
E-mail:-proc.pg@gebmail.com

TENDER NO. PGVCL/PROC/SMC BOX FOR CT OPERATED METER & Junction Box/867

| | | | |
|--|--|---|--|
| | | Single Phase - 04 Consumers: Incoming = Upto 35 sq.mm Outgoing = Upto 10 sq.mm | |
|--|--|---|--|

Signature of Tenderer

Company's Round Seal

Date:

Place:



PASCHIM GUJARAT VIJ COMPANY LIMITED

REGD. & CORPORATE OFFICE:- "PASCHIM GUJARAT VIJ SEVA SADAN"
OFF NANA MAVVA MAIN ROAD, LAXMINAGAR, RAJKOT-360004
CIN U40102GJ2003SGC042908

Telephone Nos:-0281-2380425/427/2360182
Website:-www.pgvcl.com

Fax No:-0281-2368175
E-mail:-proc.pg@gebmail.com

TENDER NO. PGVCL/PROC/SMC BOX FOR CT OPERATED METER & Junction Box/867

ANNEXURE B

| TEST REQUIREMENT FOR SERVICE CONNECTION BOX | Reference Standards |
|---|-------------------------------|
| <i>ROUTINE TEST</i> | |
| Protection against electric shock | IS 14772 |
| Provision for earthing | - Do - |
| <i>ACCEPTANCE TESTS (Random samples 10 nos. to be selected)</i> | |
| Marking (Name, Trade mark) | - Do - |
| Protection against electric shock | - Do - |
| Provision for earthing | - Do - |
| Construction and Dimension verification | - Do - |
| Heat distortion temperature (min.150 ⁰ C) (On any one sample) | IS 13411 |
| Self Extinguishing (On any one sample) | IS: 4249 |
| | |
| <i>TYPE TEST</i> | |
| Marking | IS: 14772 |
| Dimensions | - Do - |
| Protection against electric shock | - Do - |
| Provision for earthing | - Do - |
| Construction | - Do - |
| Resistance to ageing, to humid conditions, ingress of Solid objects and to harmful ingress of water | - Do - |
| Mechanical strength | - Do - |
| Resistance to heat | - Do - |
| Resistance of insulating material to abnormal heat and fire | - Do - |
| Resistance to rusting | - Do - |
| Resistance of tracking | - Do - |
| Heat distortion temperature (min.150 ⁰ C) | IS 13360 (Part VI Sec III) |
| Self Extinguishing | IS: 4249 |
| Material Identification | CIPET |

Signature of Tenderer

Company's Round Seal

Date:

Place: