



NOTE :-

1. APPLICABLE STANDARD	IS 6300 / 1969
DESIGNATION	C FIG-3
2. COLOUR OF GLAZE	BROWN
3. SIZE OF INSULATOR	MM 140 X 85
4. LENGHT	MM 140
5. DIAMETER	MM 86
6. CABLE HOLD	MM 25
7. MIN FAILING LOAD	KN 88
8. P.F. WITHSTAND VOLTAGE DRY KV	27 (rms)
9. P.F. WITHSTAND VOLTAGE WET KV	15 (rms)
10. MARKING AS PER IS	IS 6300 / 1969 33 KN MONTH / YEAR
11. ALL DIMENSION ARE IN	MM

[Signature]
 Chief Engineer (Material)
 PGVCL, Corporate Office
 Rajkot.

Tender No. PGVCL/PROC/HT-LT Stay & LT Shackle Insulator/999



PASCHIM GUJARAT VIJ COMPANY LIMITED

DRAWING 1

HT- STAY (GUY) INSULATOR