


NOTE: The Portions marked ——— shall be engaged.

SHACKLE INSULATOR


 Chief Engineer (Material)
 PGVCL, Corporate Office
 Rajkot.

NOTE :-

- | | |
|---|--|
| 1. APPLICABLE STANDARD | IS 1445 / 1977 |
| DESIGNATION | I PIG-3 |
| 2. COLOUR OF GLAZE | BROWN |
| 3. SIZE OF INSULATOR | MM 90 X 75 |
| 4. MIN FAILING LOAD | KN 11.5 |
| 5. P.F. WITHSTAND VOLTAGE DRY KV | 23 (rms) |
| 6. P.F. WITHSTAND VOLTAGE WET KV | 10 (rms) |
| 7. V.P. PUNCTURE WITH STAND VOLTAGE WET | 1.3X The actual dry flash over voltage |
| 8. MARKING AS PER IS | IS 1445 / 1977
11 SKN
MONTH / YEAR |
| 11 ALL DIMENSION ARE | MM |

Tender No. PGVCL/PROC/HT-LT Stay & LT Shackle Insulator/999



PASCHIM GUJARAT VIJ COMPANY LIMITED

DRAWING NO.

L.T. SHACKLE INSULATOR